



## **NO CERTIFICATE – NO CARRIAGE**

AFRA has always advocated via training that LP Gas Cylinders must be emptied prior to transportation.

Dangerous Goods Regulations states that such goods must not be transported in an enclosed freight container, enclosed vehicle or enclosed compartment of a vehicle unless the vehicle is ventilated to prevent the build up of vapours that are likely to increase risk.

Despite this warning under the Australian Dangerous Goods Code, the cylinder may be transported as long as it is gas free and completely empty. The cylinder must have a certificate which has been issued from a Gas Cylinder Test Station certified by Standards Australia stating that it is empty.

A list of Test Stations is available from the following website :  
<http://standardsmark.saiglobal.com/CertifiedProducts/default.aspx?CategoryID=6&iID=ucLicenceList>

We also recommend doing a on-line search of the Yellow pages using Gas Cylinder Test Station as your keyword and entering the State that you are in. Please be aware that the previous link is no longer operational.

\* \* \* \* \*